

TOWN OF AUBURN LABORATORY ANALYSIS REPORT

Parameter	Result	Date Analyzed	Health Hazard Standard
2,4-D	ND	7/15/2024	70 ug/L
2,4,5-TP (Silvex)	ND	7/15/2024	50 ug/L
ADONA	ND	7/16/2024	
Alachlor	ND	7/19/2024	2 micrograms/liter
Aldicarb	ND	7/25/2024	
Aldicarb sulfone	ND	7/25/2024	
Aldicarb sulfoxide	ND	7/25/2024	
Aldrin	ND	7/19/2024	2 micrograms/liter
Alpha-Chlordane	ND	7/19/2024	
Antimony	ND	7/16/2024	6 micrograms/liter
Arsenic	2	7/16/2024	10 micrograms/liter
Atrazine	ND	7/19/2024	EPA 3 microgram/liter
Barium (Total)	0.58	7/16/2024	2 milligrams/liter
Benzene	ND	7/22/2024	5 ug/L
Benzo(a)pyrene	ND	7/19/2024	2 micrograms/liter
Beryllium	ND	7/16/2024	4 micrograms/liter
Bromobenzene	ND	7/22/2024	
Bromochloromethane	ND	7/22/2024	
Bromodichloromethane	ND	7/22/2024	80 ug/L
Bromoform	ND	7/22/2024	80 ug/L
Bromomethane	ND	7/22/2024	
Butachlor	ND	7/19/2024	
n-Butylbenzene	ND	7/22/2024	
sec-Butylbenzene	ND	7/22/2024	
tert-Butylbenzene	ND	7/22/2024	
Cadmium	ND	7/16/2024	5 micrograms/liter
Carbaryl	ND	7/25/2024	
Carbofuran	ND	7/25/2024	40 micrograms/liter
Carbon Tetrachloride	ND	7/25/2024	5 ug/L
Chlordane	ND	7/17/2024	2 micrograms/liter
Chlorobenzene	ND	7/22/2024	100 ug/L
Chloroethane	ND	7/22/2024	
Chloroform	ND	7/22/2024	80 ug/L
Chloromethane	ND	7/22/2024	
Chlorotoluene (2)	ND	7/22/2024	
Chlorotoluene (4)	ND	7/22/2024	
Chromium	ND	7/12/2024	100 micrograms/liter
1,1,1-PP3DUs	ND	7/16/2024	
9C-PP3ONS	ND	7/16/2024	
Copper	78	7/15/2024	1300 micrograms/liter
Dalapon	ND	7/15/2024	0.2 milligrams/liter
Deethylatrazine	ND	7/19/2024	
Deisopropylatrazine	ND	7/19/2024	
Di(2-ethylhexyl) adipate	ND	7/19/2024	400 ug/L
Di(2-ethylhexyl) phthalate	ND	7/19/2024	6 ug/L
1,2 Dibromo-3-Chloropropane (DBCP)	ND	7/22/2024	
1,2 Dibromoethane (EDB)	ND	7/22/2024	0.05 ug/L
Dibromochloromethane	ND	7/22/2024	80 ug/L
Dibromomethane	ND	7/22/2024	
Dicamba	ND	7/15/2024	300 micrograms/liter
1,3 Dichlorobenzene	ND	7/22/2024	
1,2 Dichlorobenzene	ND	7/22/2024	600 ug/L
1,4 Dichlorobenzene	ND	7/22/2024	75 ug/L
Dichlorodifluoromethane	ND	7/22/2024	
1,1, Dichloroethane	ND	7/22/2024	
1,2 Dichloroethane	ND	7/22/2024	5 ug/L
1,1 Dichloroethene	ND	7/22/2024	7 ug/L
cis-1,2 Dichloroethene	ND	7/22/2024	70 ug/L
Trans-1,2 Dichloroethene	ND	7/22/2024	100 ug/L
Dichloromethane	ND	7/22/2024	5 ug/L
1,2 Dichloropropane	ND	7/22/2024	5 ug/L
1,3 Dichloropropane	ND	7/22/2024	
2,2 Dichloropropane	ND	7/22/2024	
1,1 Dichloropropane	ND	7/22/2024	
1,3 Dichloropropene (Total cis+trans)	ND	7/22/2024	
Dieldrin	ND	7/19/2024	
Dinoseb	ND	7/15/2024	7 micrograms/liter
Endothal	ND	7/15/2024	0.1 parts per million
Endrin	ND	7/19/2024	2 micrograms/liter
Ethyl Benzene	ND	7/22/2024	700 ug/L
Fluoride	0.033	7/11/2024	4 milligrams/liter
gamma-BHC (Lindane)	ND	7/19/2024	0.2 micrograms/liter
Gamma-Chlordane	ND	7/19/2024	
Glyphosate (Round-up)	ND	7/17/2024	700 parts per billion
Heptachlor	ND	7/19/2024	0.4 micrograms/liter
Heptachlor epoxide	ND	7/19/2024	0.2 micrograms/liter
Hexachlorobenzene	ND	7/19/2024	1 microgram/liter
Hexachlorobutadiene	ND	7/22/2024	
Hexachlorocyclopentadiene	ND	7/19/2024	0.05 parts per million
HFPO DA	ND	7/16/2024	
3-Hydroxycarbofuran	ND	7/25/2024	
Isopropylbenzene	ND	7/22/2024	
p-isopropyltoluene	ND	7/22/2024	
Lead	0.59	7/15/2024	15 micrograms/liter
Manganese (total)	9.3	7/18/2024	50 ug/L
Methomyl	ND	7/25/2024	
Mercury	ND	7/16/2024	2 micrograms/liter
Methoxychlor	ND	7/19/2024	40 micrograms/liter
Metolachlor (Dual)	ND	7/19/2024	
Metribuzin	ND	7/19/2024	
MTBE	ND	7/22/2024	
Naphthalene	ND	7/22/2024	
NEFOSAA	ND	7/16/2024	
NMeFOSAA	ND	7/16/2024	
Nickel (total)	6	7/16/2024	100 micrograms/liter
Nitrate	3.8	5/7/2024	10 PPM
Oxamyl	ND	7/25/2024	0.2 parts per million
PCB (Total)	0	7/17/2024	0.5 ug/L
Pentachlorophenol	ND	7/15/2024	1 microgram/liter
PFBs	ND	7/16/2024	
PFDA	ND	7/16/2024	
PFDaA	ND	7/16/2024	
PFHpA	ND	7/16/2024	
PFHxA	ND	7/16/2024	
PFHxS	ND	7/16/2024	
PFNA	ND	7/16/2024	
PFOA	ND	7/16/2024	
PFOS	ND	7/16/2024	
PFTA	ND	7/16/2024	
PFTrDA	ND	7/16/2024	
PFUnA	ND	7/16/2024	
Picloram	ND	7/15/2024	500 micrograms/liter
Propachlor	ND	7/19/2024	
n-Propylbenzene	ND	7/22/2024	
Selenium (total)	5.3	7/18/2024	50 micrograms/liter
Styrene	ND	7/22/2024	100 ug/L
1,1,1,2 Tetrachloroethane	ND	7/22/2024	
1,1,1,2, Tetrachloroethane	ND	7/22/2024	
Tetrachloroethene	ND	7/22/2024	5 ug/L
Thallium	ND	7/16/2024	2 micrograms/liter
Toluene	ND	7/22/2024	1000 ug/L
Toxaphene	ND	7/17/2024	3 micrograms/liter
1,2,3 Trichlorobenzene	ND	7/22/2024	
1,2,4 Trichlorobenzene	ND	7/22/2024	70 ug/L
1,1,1 Trichloroethane	ND	7/22/2024	200 ug/L
1,1,2 Trichloroethane	ND	7/22/2024	5 ug/L
Trichloroethene	ND	7/22/2024	5 ug/L
Trichlorofluoromethane	ND	7/22/2024	5 ug/L
1,2,3 Trichloropropane	ND	7/22/2024	
1,2,4 Trimethylbenzene	ND	7/22/2024	
1,3,5 Trimethylbenzene	ND	7/22/2024	
Turbidity (SDWA 200.8)	7.7	7/12/2024	1 NTU
Turbidity (SDWA 200.7 & 200.8)	0.68 NTU	7/12/2024	
Turbidity screening SDWA 200.7	ND	7/12/2024	1 NTU
Turbidity screening SDWA 200.8	ND	7/12/2024	1 NTU
Vinyl Chloride	ND	7/22/2024	0.2 ug/L
Xylene (total)	ND	7/22/2024	10000 ug/L

Northern Lake Service, Inc.	Eau Claire City-County Health Dept.
Sample Site: Fill Site	Sample Site: Pressure Tank Tap
Sample Collected: 7/9/24	Sample Collected: 5/2/2024